



**Scottsdale Fire Department**  
Fire and Life Safety Division

Fire Plan Review  
7447 E. Indian School Road

PHONE 480-312-2500  
Scottsdale, AZ 85251

**ALL Compressed Gasses (Bulk) Submittal (Interior of Building)**

The following procedure for plan submittal shall be followed:

1. Floor Plan demonstrating the following:
  - a. Written narrative on scope of work
  - b. Location of modules at termination points
  - c. Notification devices installed
  - d. Contractor name, phone #, address, contact person, Lic. & Class
  - e. Note: "Gas detection system to be monitored by fire alarm" when alarm is provided in building
2. Provide ventilation calculations for interior tank install
3. Manufacture data sheet(s) on tank(s)
4. Manufacture data sheets on modules/devices

If you have additional questions please contact Fire Plan Review at 480-312-2500.



**Scottsdale Fire Department**  
Fire and Life Safety Division

Fire Plan Review  
7447 E. Indian School Road

PHONE 480-312-2500  
Scottsdale, AZ 85251

**ALL Compressed Gasses (Bulk) Submittal (Exterior of Building)**

The following procedure for plan submittal shall be followed:

1. Site Plan demonstrating the following:
  - a. Location of tank in conjunction to building
  - b. Screen wall
  - c. Scope of work
2. Floor Plan demonstrating the following:
  - a. Location of modules at termination points
  - b. Notification devices installed
3. Manufacture data sheet(s) on tank(s)
4. Manufacture data sheets on modules/devices

If you have additional questions please contact Fire Plan Review at 480-312-2500.