Scottsdale Fire Department



declaration.

480-312-1825

Fireallplanreview@scottsdaleaz.gov

Five or Less Fire Alarm Declaration

The purpose of this declaration is for installing contractors to obtain a "no-plan permit" for fire alarm systems when the scope of work is limited to the addition or alteration of 0-5 fire alarm initiating devices and notification appliances in buildings with existing fire alarm systems. By signing this declaration, the installing contractor declares that they are not adding or altering more than five (5) initiating devices and notification appliances in an existing fire alarm system and the proposed scope of work complies with the requirements of National Fire Protection Association (NFPA) Standard 72.

SECTION I: FIVE OR LESS FIRE ALARM DEVICES ADDED OR ALTERED Licensed Contractor Declaration: (print full name), certify that this Tenant Improvement (TI) fire alarm scope of work does not exceed five (5) devices and appliances and all work will be performed in accordance with the current editions of the International Building and Fire Codes and NFPA 72. I certify that the fire alarm system installation will comply with the following criteria: 1. The scope of work does not include any fire alarm components other than initiating devices and notification appliances. This includes, but is not limited to, fire alarm control units, wireless communicators, power supplies, remote annunciators, etc. 2. All initiating devices will be located in accordance with the applicable edition of NFPA 72. 3. All notification appliances will be located in accordance with the applicable edition of NFPA 72. 4. The position of devices relative to architectural features such as soffits, beams, partitions and walls will comply with the applicable edition of NFPA 72. 5. All devices and appliances will be listed and approved. 6. Wiring will not be concealed until after the inspector has passed rough Inspection. 7. Voltage drop is within the allowable limits. 8. Batteries are capable of supporting the system modifications. 9. Compatibility of appliances and devices are in accordance with the requirements of the Fire Alarm Control Unit (FACU) manufacturer's specifications. 10. At the time of inspection, manufacturer's specifications of installed equipment will be available. I understand that final approval will be subject to the Final Inspection of the fire alarm system. Licensed Contractor Signature: Submittal of drawings (and calculations, if necessary) will be required if installation is found not to be in compliance with this