



Scottsdale Fire Department

480-312-1825

Fireallplanreview@scottsdaleaz.gov

Five or Less Fire Sprinkler Declaration

The purpose of this document is for contractors to obtain a “no-plan permit” for fire sprinkler systems when the scope of work is limited to the addition or alteration of 0 – 5 sprinklers in existing, sprinklered buildings. By signing this declaration, the installing contractor declares they are not adding or altering more than five (5) sprinklers in the existing fire sprinkler system and the proposed work complies with the requirements of National Fire Protection Association (NFPA) Standards 13, 13R or 13D.

SECTION I: FIVE OR LESS SPRINKLERS ADDED OR ALTERED

Licensed Contractor Declaration:

I, _____ (print full name), certify that this residential home or commercial tenant improvement (TI) fire sprinkler scope of work does not exceed five (5) sprinklers and all work will be performed in accordance with the current editions of the International Building and Fire Codes and NFPA 13, 13R or 13D Standards.

I certify that the fire sprinkler system installation will comply with the following criteria:

1. The position of sprinklers relative to architectural features such as soffits, beams, partitions, fans, walls, etc. will comply with the applicable requirements of NFPA 13, 13R, or 13D.
2. The proposed work will not make the system more hydraulically demanding.
3. New sprinklers will be standard spray and the orifice size; temperature rating, and response characteristics will match the existing sprinklers.
4. No more than 2 sprinklers will be fed by a 1-inch outlet for light hazard occupancies and no more than 1 sprinkler will be fed by a 1-inch outlet for ordinary hazard occupancies.
5. The protection area per sprinkler will not exceed existing spacing and will be limited to the applicable requirements of NFPA 13, 13R or 13D.
6. Sprinklers will be Quick Response except as allowed by NFPA 13.
7. The piping will not be concealed until after the rough inspection is passed.
8. New flexible sprinkler hose will not be installed.

I understand that final approval will be subject to the Final Inspection of the fire sprinkler system.

Licensed Contractor Signature:

Submittal of drawings (and calculations, if necessary) will be required if installation is found not to be in compliance with this declaration.